



# THE UNIVERSITY OF SOUTHERN MISSISSIPPI

December 15, 2020

ADDENDUM 1 TO BID 21-38

WALK-IN FREEZER

Deidre Edwards

Buyer, Procurement and Contract Services

BID 21-38 is being amended to update the REFRIGERATION section, particularly the voltage requirements which are highlighted below, on page 6 of the bid specifications to the following:

**REFRIGERATION:**

Refrigeration components shall consist of a 10 hp condensing unit of the Scroll type for the walk-in freezer, ThermoKool model BCH0100LDACZ. Condensing unit shall be remote, self contained, factory assembled and UL approved. The condensers shall be air-cooled. Condensing unit voltage to be 460v 3ph. Condensing units shall be installed in a position designated by the owner. **All measurements must be field verified by the DEALER prior to construction by ThermoKool.**

Shall include two (2) evaporators forced air type with air flow parallel to the walk-in ceiling. The freezer evaporators shall be a standard low profile series, model BEL0170BS6EEA. The evaporator to include single speed, electronically commutated, motors. Evaporator coil components shall be housed in heavy gauge aluminum housing. Freezer evaporator voltage to be 460v 1ph.

**PROCUREMENT SERVICES**

118 College Drive #5003 • Hattiesburg, MS • 39406-0001

*Hattiesburg • Long Beach • Ocean Springs • Biloxi • John C. Stennis Space Center*