

THE UNIVERSITY OF SOUTHERN MISSISSIPPI

April 21st, 2022

ADDENDUM 1 TO BID 22-38

This addendum provides answers to questions submitted by prospective bidders.

Answers are below in red.

John Leggett, Buyer

- a. FIltration system. Specify what it must include: For example, filter, pump, UV light, water heater etc the requirement is a physical filter with a large and small gate (two-step) filter for removing debris, particulates, etc. The smaller filter, the polishing filter, should be sub 1 micron. The water should remain clean and be able to recirculate. Filtration should be capable of matching the water flow rate for recirculation.
- b. Polymer composite defined. All specimens seems to be monolythic composites, are honeycomb structures covered? Honeycomb structures are not the priority right now. However, we do make cored flat panels from time to time.
- c. Clarify what is meant be X-Y gantry and what is required This is a mix-up in language from conferring with different suppliers. The system needs to scan the full dimension of the panel whether it is a gantry or flatbed scanner configuration is not important.
- d. PE and Through transmission are discussed but only X-Y axes are required, please detail the scanner configuration you require. Through transmission is not required. What is most important is the ability to obtain C-scan data on flat monolithic composite panels having maximum dimensions 40" x 48" x 1.0" (length x width x thickness). Pulse-echo or phased array probes are acceptable. Regardless of your response, we would like to know what the minimum defect size detection (resolution) is for that particular configuration.
- e. Is a manual Z axis required? No
- f. For Through-Transmission work, what is required? Not required
- g. Do you need a gimbal/gimbal adjustment? Not required unless your system requires it.

PROCUREMENT SERVICES